

## 初野浄水場 流量水質報告書

平成30年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,640	2.87	7.55	—	23,950	19,530	2.29	7.47	8.30	0.00	0.00	
2	34,890	2.92	7.54	—	23,590	18,750	2.31	7.49	8.40	0.00	0.00	
3	35,870	2.80	7.56	—	24,010	19,810	2.28	7.49	8.60	0.00	0.00	
4	35,020	2.71	7.54	—	23,400	20,060	2.12	7.49	9.80	0.00	0.00	
5	37,030	2.70	7.55	—	24,850	21,000	2.20	7.52	9.50	2.40	0.00	
6	33,440	2.62	7.54	—	22,380	19,290	2.00	7.47	9.50	0.00	0.00	
7	35,210	2.60	7.54	—	23,800	19,660	2.00	7.45	9.30	0.00	0.00	
8	36,050	2.61	7.56	—	24,790	19,590	1.83	7.47	9.60	0.00	0.00	
9	36,120	2.48	7.55	—	24,900	19,290	1.78	7.48	9.60	0.00	0.00	
10	36,070	2.43	7.56	—	24,310	20,130	1.44	7.48	9.80	0.00	0.00	
11	35,710	2.41	7.59	—	23,380	19,980	1.36	7.48	9.60	0.00	0.00	
12	36,060	2.40	7.60	—	24,390	20,460	1.26	7.49	10.00	2.40	0.00	
13	35,770	2.35	7.57	—	23,950	20,290	1.34	7.51	10.10	0.00	0.00	
14	36,350	2.37	7.59	—	24,520	20,420	1.18	7.50	10.10	0.00	0.00	
15	35,930	2.41	7.54	—	24,310	19,560	1.15	7.46	12.00	0.00	0.00	
16	35,510	2.35	7.59	—	24,420	19,420	1.12	7.51	10.30	0.00	0.00	
17	36,890	2.34	7.58	—	24,880	20,940	1.12	7.49	10.20	0.00	0.00	
18	34,850	2.34	7.57	—	23,140	19,940	1.08	7.45	9.90	0.00	0.00	
19	35,830	2.35	7.56	—	24,330	19,970	1.06	7.46	10.10	2.40	0.00	
20	35,900	2.31	7.58	—	23,360	20,410	1.04	7.47	10.50	0.00	0.00	
21	35,420	2.29	7.56	—	23,760	20,120	1.02	7.47	11.30	0.00	0.00	
22	36,460	2.27	7.54	—	24,210	20,550	0.95	7.46	11.80	0.00	0.00	
23	35,000	2.25	7.56	—	23,440	19,090	0.93	7.46	11.60	0.00	0.00	
24	34,980	2.24	7.53	—	23,880	19,690	0.93	7.43	11.40	0.00	0.00	
25	35,890	2.26	7.51	—	24,220	20,270	0.90	7.44	11.30	0.00	0.00	
26	34,280	2.32	7.54	—	23,450	19,510	1.00	7.45	11.30	2.40	0.00	
27	36,730	2.29	7.53	—	24,040	22,090	1.02	7.45	12.00	0.00	0.00	
28	34,920	2.25	7.51	—	23,120	19,850	0.94	7.43	12.10	0.00	0.00	
29	34,280	2.23	7.51	—	22,640	19,140	1.02	7.42	12.30	0.00	0.00	
30	33,970	2.28	7.50	—	22,440	19,290	1.03	7.43	12.60	0.00	0.00	
合計	1,066,070	—	—	—	715,860	598,100	—	—	—	9.60	0.00	
最大	37,030	2.92	7.60	—	24,900	22,090	2.31	7.52	12.60	2.40	0.00	
最小	33,440	2.23	7.50	—	22,380	18,750	0.90	7.42	8.30	0.00	0.00	
平均	35,536	2.44	7.55	—	23,862	19,937	1.39	7.47	10.43	0.32	0.00	

## 初野浄水場 流量水質報告書

平成30年5月分

項目 日	原 水 関 係				沈澱池 流量 (m <sup>3</sup> /日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	33,820	2.83	7.46	—	21,990	19,250	1.04	7.43	13.50	0.00	0.00	
2	32,520	2.27	7.49	—	20,940	17,120	1.01	7.41	13.10	2.40	0.00	
3	34,010	2.32	7.46	—	22,690	18,560	1.00	7.38	13.10	0.00	0.00	
4	35,290	2.33	7.43	—	23,760	18,800	1.00	7.39	13.50	0.00	0.00	
5	35,030	2.37	7.44	—	23,680	18,730	1.00	7.39	13.20	0.00	0.00	
6	35,250	2.33	7.43	—	23,910	19,120	1.02	7.40	13.60	0.00	0.00	
7	34,550	2.23	7.40	—	23,530	18,780	1.02	7.35	13.40	0.00	0.00	
8	34,900	2.20	7.37	—	23,780	19,470	1.13	7.35	13.00	0.00	0.00	
9	34,540	2.23	7.33	—	23,610	19,110	1.15	7.34	12.70	0.00	0.00	
10	35,180	2.19	7.35	—	24,440	19,810	1.28	7.33	12.60	2.40	0.00	
11	34,860	2.12	7.35	—	23,370	20,000	1.21	7.35	12.90	0.00	0.00	
12	35,240	2.12	7.33	—	23,040	20,450	1.24	7.35	13.20	0.00	0.00	
13	34,580	2.14	7.35	—	23,150	19,490	1.22	7.31	13.30	0.00	0.00	
14	34,300	2.26	7.33	—	23,220	19,100	1.25	7.31	13.20	0.00	0.00	
15	35,310	2.27	7.36	—	23,680	20,160	1.23	7.35	13.90	0.00	0.00	
16	33,970	2.41	7.33	—	22,360	19,390	1.33	7.29	13.80	0.00	0.00	
17	35,380	2.40	7.31	—	23,000	20,530	1.35	7.28	14.20	2.40	0.00	
18	34,010	2.42	7.31	—	22,940	19,220	1.30	7.26	14.20	0.00	0.00	
19	35,390	2.47	7.29	—	24,080	19,550	1.25	7.29	13.90	0.00	0.00	
20	34,660	2.26	7.32	—	23,180	19,110	1.28	7.30	14.20	0.00	0.00	
21	34,430	2.42	7.34	—	23,290	18,960	1.30	7.31	14.20	0.00	0.00	
22	34,760	2.44	7.34	—	23,230	19,780	1.22	7.30	14.60	0.00	0.00	
23	34,330	2.49	7.33	—	22,580	20,220	1.32	7.30	14.50	0.00	0.00	
24	35,080	2.38	7.32	—	23,840	19,780	1.40	7.30	14.60	2.40	0.00	
25	35,080	2.59	7.33	—	23,320	20,010	1.37	7.33	15.10	0.00	0.00	
26	35,280	1.80	7.30	—	23,620	20,560	1.20	7.31	15.20	0.00	0.00	
27	35,480	2.21	7.36	—	23,980	19,430	1.48	7.35	15.10	0.00	0.00	
28	34,560	2.28	7.40	—	23,500	18,990	1.46	7.36	15.10	0.00	0.00	
29	35,390	2.46	7.40	—	24,110	20,330	1.56	7.38	15.40	0.00	0.00	
30	34,680	2.38	7.36	—	22,820	19,810	1.44	7.33	15.40	0.00	0.00	
31	35,420	2.41	7.34	—	23,890	20,010	1.61	7.32	15.40	2.40	0.00	
合計	1,077,280	—	—	—	722,530	603,630	—	—	—	12.00	0.00	
最大	35,480	2.83	7.49	—	24,440	20,560	1.61	7.43	15.40	2.40	0.00	
最小	32,520	1.80	7.29	—	20,940	17,120	1.00	7.26	12.60	0.00	0.00	
平均	34,751	2.32	7.36	—	23,307	19,472	1.25	7.34	13.97	0.39	0.00	

## 初野浄水場 流量水質報告書

平成30年6月分

項目 日	原 水 関 係				沈澱池 流量 (m <sup>3</sup> /日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	34,860	2.48	7.36	—	23,360	19,670	1.70	7.35	15.40	0.00	0.00	
2	35,250	2.74	7.33	—	23,870	19,960	1.74	7.35	15.60	0.00	0.00	
3	34,620	2.77	7.34	—	23,500	18,970	1.86	7.33	15.50	0.00	0.00	
4	34,920	2.95	7.31	—	23,710	19,200	1.88	7.32	15.70	0.00	0.00	
5	35,000	2.65	7.31	—	23,780	19,940	1.98	7.31	15.80	0.00	0.00	
6	34,170	2.67	7.20	—	22,720	19,910	1.58	7.18	13.90	0.00	0.00	
7	35,290	2.52	7.21	—	23,030	20,130	1.57	7.17	13.70	2.40	0.00	
8	35,040	2.52	7.20	—	22,610	20,150	1.58	7.19	13.70	0.00	0.00	
9	35,360	2.53	7.22	—	23,400	20,550	1.51	7.17	13.10	0.00	0.00	
10	35,790	2.66	7.15	—	23,930	19,650	1.53	7.17	12.90	0.00	0.00	
11	34,370	2.83	7.15	—	23,300	18,290	1.68	7.16	13.00	0.00	0.00	
12	34,990	2.74	7.18	—	23,590	19,430	1.73	7.20	13.30	0.00	0.00	
13	35,020	3.18	7.27	—	23,400	19,780	2.26	7.27	16.30	0.00	0.00	
14	34,660	3.22	7.29	—	22,730	20,460	2.37	7.29	17.10	0.00	0.00	
15	34,430	3.20	7.30	—	22,760	20,810	2.46	7.27	16.70	2.40	0.00	
16	35,380	3.07	7.23	—	23,940	20,480	2.31	7.21	16.30	0.00	0.00	
17	34,800	2.96	7.25	—	23,700	20,200	2.13	7.24	16.20	0.00	0.00	
18	33,810	2.82	7.25	—	22,920	18,340	2.22	7.21	16.10	0.00	0.00	
19	34,870	2.13	7.21	—	23,080	20,800	1.34	7.14	14.10	0.00	0.00	
20	35,720	2.21	7.19	—	23,950	21,080	1.31	7.15	13.90	0.00	0.00	
21	34,730	2.23	7.15	—	23,220	20,130	1.28	7.12	13.60	0.00	0.00	
22	34,610	2.21	7.22	—	22,790	20,830	1.30	7.20	13.70	2.40	0.00	
23	35,570	2.19	7.20	—	23,240	20,880	1.26	7.15	13.60	0.00	0.00	
24	36,330	2.35	7.19	—	24,390	20,070	1.21	7.19	13.80	0.00	0.00	
25	35,380	2.31	7.17	—	23,910	20,180	1.20	7.18	13.80	0.00	0.00	
26	35,720	2.31	7.19	—	23,670	20,790	1.23	7.17	13.90	0.00	0.00	
27	36,130	2.24	7.14	—	23,790	20,910	1.12	7.08	13.70	0.00	0.00	
28	35,640	2.15	7.17	—	24,190	20,830	1.10	7.13	13.70	2.40	0.00	
29	35,940	2.20	7.17	—	23,630	21,020	1.13	7.15	13.80	0.00	0.00	
30	35,910	2.14	7.14	—	23,340	21,260	1.06	7.09	13.60	0.00	0.00	
合計	1,054,310	—	—	—	703,450	604,700	—	—	—	9.60	0.00	
最大	36,330	3.22	7.36	—	24,390	21,260	2.46	7.35	17.10	2.40	0.00	
最小	33,810	2.13	7.14	—	22,610	18,290	1.06	7.08	12.90	0.00	0.00	
平均	35,144	2.57	7.22	—	23,448	20,157	1.62	7.20	14.52	0.32	0.00	

## 初野浄水場 流量水質報告書

平成30年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	35,390	2.08	7.13	—	22,930	19,970	1.05	7.06	13.70	0.00	0.00	
2	35,810	2.05	7.12	—	23,880	20,220	0.98	7.08	13.60	0.00	0.00	
3	36,960	2.04	7.15	—	23,460	21,640	0.97	7.11	13.70	0.00	0.00	
4	37,960	2.04	7.10	—	23,770	21,430	0.95	7.07	13.30	0.00	0.00	
5	35,350	2.03	7.10	—	23,560	20,650	0.85	7.10	13.50	2.40	0.00	
6	35,310	1.29	7.09	—	24,380	20,910	0.85	7.10	13.50	0.00	0.00	
7	35,020	1.32	7.07	—	24,290	20,230	0.83	7.05	13.60	0.00	0.00	
8	35,390	1.38	7.06	—	24,560	19,930	0.78	7.04	13.80	0.00	0.00	
9	34,330	1.47	7.08	—	23,810	19,330	0.79	7.04	13.90	0.00	0.00	
10	34,150	1.78	7.10	—	23,590	20,800	0.80	7.06	14.10	0.00	0.00	
11	36,130	1.77	7.14	—	23,990	21,060	0.94	7.10	14.00	0.00	0.00	
12	33,900	1.70	7.07	—	22,290	18,370	1.27	7.04	13.70	2.40	0.00	
13	37,430	1.84	7.12	—	25,780	21,690	0.96	7.07	13.90	0.00	0.00	
14	36,960	1.79	7.11	—	25,550	21,680	0.94	7.08	13.90	0.00	0.00	
15	37,980	1.79	7.07	—	26,110	21,730	0.80	7.12	14.00	0.00	0.00	
16	36,110	1.77	7.11	—	25,010	20,410	0.68	7.06	14.30	0.00	0.00	
17	37,000	1.75	7.09	—	25,570	21,180	0.68	7.05	14.50	0.00	0.00	
18	36,110	1.77	7.09	—	23,550	21,590	0.71	7.07	13.90	0.00	0.00	
19	36,460	1.99	7.20	—	23,350	21,460	0.90	7.16	19.90	2.40	0.00	
20	36,650	1.86	7.12	—	23,770	21,360	0.76	7.09	17.70	0.00	0.00	
21	34,490	1.83	7.15	—	22,840	21,240	0.82	7.11	17.70	0.00	0.00	
22	34,340	1.84	7.14	—	22,110	20,880	0.65	7.13	17.80	0.00	0.00	
23	34,320	1.77	7.12	—	22,290	21,050	0.71	7.10	17.80	0.00	0.00	
24	36,830	1.81	7.11	—	24,880	20,770	0.66	7.12	17.70	0.00	0.00	
25	36,820	1.82	7.10	—	25,640	20,920	0.63	7.08	17.80	0.00	0.00	
26	36,770	1.74	7.08	—	25,270	20,860	0.58	7.07	17.80	2.40	0.00	
27	36,710	1.83	7.13	—	24,760	21,340	0.55	7.14	17.80	0.00	0.00	
28	35,190	1.77	7.05	—	23,560	20,490	0.56	7.10	17.70	0.00	0.00	
29	35,420	2.13	7.03	—	24,290	20,040	0.68	7.09	17.90	0.00	0.00	
30	34,990	2.06	7.08	—	24,000	19,900	0.83	7.06	18.00	0.00	0.00	
31	36,260	2.14	7.08	—	24,850	21,350	0.69	7.12	18.20	0.00	0.00	
合計	1,112,540	—	—	—	747,690	644,480	—	—	—	9.60	0.00	
最大	37,980	2.14	7.20	—	26,110	21,730	1.27	7.16	19.90	2.40	0.00	
最小	33,900	1.29	7.03	—	22,110	18,370	0.55	7.04	13.30	0.00	0.00	
平均	35,888	1.81	7.10	—	24,119	20,790	0.80	7.09	15.57	0.31	0.00	

## 初野浄水場 流量水質報告書

平成30年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,560	2.04	7.09	—	25,060	21,110	0.65	7.07	18.10	0.00	0.00	
2	35,480	1.97	7.11	—	23,730	21,590	0.58	7.05	18.10	2.40	0.00	
3	34,590	1.99	7.06	—	23,010	20,840	0.58	7.06	18.20	0.00	0.00	
4	35,320	1.97	7.11	—	23,440	21,450	0.61	7.10	18.30	0.00	0.00	
5	34,290	2.03	7.08	—	23,090	20,490	0.56	7.06	18.30	0.00	0.00	
6	34,530	2.07	7.03	—	23,230	20,320	0.62	7.05	18.10	0.00	0.00	
7	35,250	2.04	7.02	—	24,530	20,740	0.54	7.06	17.90	0.00	0.00	
8	33,850	2.08	7.03	—	23,500	19,790	0.64	7.08	17.90	0.00	0.00	
9	35,180	1.92	7.03	—	24,280	20,610	0.71	7.10	18.10	2.40	0.00	
10	34,980	3.80	6.95	—	23,560	20,860	1.92	6.99	20.00	0.00	0.00	
11	34,380	5.87	6.95	—	24,080	20,150	5.14	6.94	19.70	0.00	0.00	
12	34,230	5.52	7.02	—	23,030	19,590	5.08	7.01	19.90	0.00	0.00	
13	34,940	5.26	7.02	—	23,770	20,150	4.55	7.00	19.90	0.00	0.00	
14	34,350	4.70	7.05	—	23,350	20,130	3.87	7.04	20.00	0.00	0.00	
15	34,570	4.53	7.05	—	23,450	20,240	3.88	7.02	20.20	0.00	0.00	
16	34,790	4.04	7.03	—	23,550	20,330	3.23	7.01	20.20	2.40	0.00	
17	33,680	3.14	7.06	—	22,840	20,070	3.28	7.12	20.20	0.00	0.00	
18	33,540	2.81	7.09	—	22,590	20,220	2.53	7.15	20.10	0.00	0.00	
19	33,860	2.84	7.12	—	23,010	19,390	2.68	7.11	19.70	0.00	0.00	
20	33,840	2.91	7.07	—	22,920	19,210	2.51	7.12	19.80	0.00	0.00	
21	34,080	2.95	7.07	—	22,210	20,550	2.41	7.09	19.90	0.00	0.00	
22	34,120	2.62	7.04	—	22,350	20,620	1.97	7.05	18.80	0.00	0.00	
23	34,170	2.59	7.07	—	22,360	20,860	1.91	7.06	18.80	2.40	0.00	
24	34,530	2.58	7.04	—	22,340	20,960	1.94	7.04	18.80	0.00	0.00	
25	34,990	2.58	7.05	—	23,560	21,320	1.68	7.07	18.90	0.00	0.00	
26	33,940	2.58	7.04	—	22,990	20,230	1.63	7.03	18.80	0.00	0.00	
27	34,050	2.57	7.01	—	23,080	19,800	1.58	6.99	18.70	0.00	0.00	
28	34,570	2.63	7.05	—	23,540	20,710	1.57	7.04	18.60	0.00	0.00	
29	34,370	2.71	7.01	—	23,610	20,230	1.58	7.04	18.60	0.00	0.00	
30	34,410	2.75	7.05	—	23,380	20,180	1.63	7.02	18.60	2.40	0.00	
31	34,260	2.64	7.05	—	22,380	20,830	1.54	7.04	18.60	0.00	0.00	
合計	1,069,700	—	—	—	721,820	633,570	—	—	—	12.00	0.00	
最大	36,560	5.87	7.12	—	25,060	21,590	5.14	7.15	20.20	2.40	0.00	
最小	33,540	1.92	6.95	—	22,210	19,210	0.54	6.94	17.90	0.00	0.00	
平均	34,506	2.99	7.05	—	23,285	20,438	2.05	7.05	19.03	0.39	0.00	

## 初野浄水場 流量水質報告書

平成30年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	34,360	2.61	7.07	—	23,060	21,030	1.33	7.06	18.50	0.00	0.00	
2	33,400	2.57	7.09	—	22,500	20,120	1.34	7.10	18.40	0.00	0.00	
3	33,570	2.46	7.06	—	22,850	20,040	1.36	7.03	18.40	0.00	0.00	
4	34,140	2.42	7.07	—	22,770	21,200	1.17	7.07	18.40	0.00	0.00	
5	33,290	2.43	7.06	—	21,950	20,860	1.26	7.09	18.50	0.00	0.00	
6	33,430	2.57	7.06	—	21,930	21,240	1.34	7.08	18.60	2.40	0.00	
7	34,610	2.52	7.04	—	22,410	21,180	1.32	7.07	18.50	0.00	0.00	
8	33,660	2.50	6.99	—	22,730	21,160	1.32	7.00	18.50	0.00	0.00	
9	34,430	2.52	7.01	—	23,630	20,630	1.29	7.05	18.40	0.00	0.00	
10	33,550	2.47	7.03	—	23,070	19,670	1.25	7.05	18.30	0.00	0.00	
11	33,820	2.59	6.95	—	23,160	20,650	1.20	7.05	18.20	0.00	0.00	
12	33,550	2.39	7.00	—	22,080	20,750	1.26	7.05	18.10	0.00	0.00	
13	34,040	2.21	7.04	—	22,340	20,930	1.31	7.07	18.10	2.40	0.00	
14	33,390	2.17	7.03	—	21,960	20,170	1.30	7.03	18.20	0.00	0.00	
15	35,730	2.19	7.02	—	23,960	20,920	1.31	7.03	18.20	0.00	0.00	
16	34,110	2.11	7.02	—	23,640	19,430	1.30	7.03	18.20	0.00	0.00	
17	35,350	2.14	7.01	—	24,400	19,920	1.31	7.04	18.30	0.00	0.00	
18	35,110	2.21	7.05	—	23,970	20,240	1.39	7.08	18.30	0.00	0.00	
19	33,840	2.40	7.09	—	22,930	20,320	1.46	7.09	18.20	0.00	0.00	
20	34,450	2.25	7.07	—	22,830	20,680	1.31	7.06	16.50	2.40	0.00	
21	38,680	2.25	7.06	—	25,880	22,880	1.38	7.09	16.40	0.00	0.00	
22	30,400	2.29	6.98	—	21,190	17,870	1.45	6.79	16.50	0.00	0.00	
23	34,340	2.38	6.99	—	22,920	19,870	1.55	7.01	16.40	0.00	0.00	
24	34,720	2.39	6.96	—	23,660	20,200	1.43	7.01	16.40	0.00	0.00	
25	34,130	2.46	6.98	—	23,490	20,020	1.41	6.97	16.30	0.00	0.00	
26	34,470	2.42	6.97	—	23,020	20,480	2.10	6.97	16.20	0.00	0.00	
27	34,640	2.44	6.99	—	23,490	20,710	1.72	7.00	18.10	0.00	0.00	
28	34,460	2.43	7.03	—	23,340	20,390	1.65	7.08	18.40	0.00	0.00	
29	33,570	2.42	6.99	—	22,030	20,890	1.47	7.05	18.40	0.00	0.00	
30	33,030	2.38	6.94	—	22,470	20,170	1.29	7.00	18.20	0.00	0.00	
合計	1,024,270	—	—	—	689,660	614,620	—	—	—	7.20	0.00	
最大	38,680	2.61	7.09	—	25,880	22,880	2.10	7.10	18.60	2.40	0.00	
最小	30,400	2.11	6.94	—	21,190	17,870	1.17	6.79	16.20	0.00	0.00	
平均	34,142	2.39	7.02	—	22,989	20,487	1.39	7.04	17.87	0.24	0.00	

## 初野浄水場 流量水質報告書

平成30年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	30,650	2.40	6.92	—	20,810	18,020	1.51	6.95	18.40	0.00	0.00	
2	32,750	2.24	7.01	—	21,940	20,210	1.71	7.08	18.50	0.00	0.00	
3	33,140	2.45	6.98	—	21,700	19,840	1.79	7.03	18.20	0.00	0.00	
4	33,410	2.56	7.00	—	22,460	20,310	1.82	7.03	18.00	0.00	0.00	
5	33,150	2.67	6.99	—	21,680	20,650	1.91	7.03	18.00	0.00	0.00	
6	33,570	2.65	7.01	—	22,570	20,830	1.83	7.04	17.50	0.00	0.00	
7	32,830	2.76	7.03	—	22,220	20,520	1.84	7.04	17.50	0.00	0.00	
8	33,130	2.83	7.03	—	22,250	20,180	1.95	7.08	17.70	0.00	0.00	
9	32,840	2.82	7.04	—	21,990	19,830	1.86	7.06	17.40	0.00	0.00	
10	33,120	2.85	7.03	—	22,230	21,070	1.89	7.04	17.40	0.00	0.00	
11	34,170	1.93	6.98	—	22,590	20,830	1.77	6.99	16.20	0.00	0.00	
12	33,980	2.05	6.95	—	23,640	20,410	1.69	7.01	16.10	0.00	0.00	
13	34,580	2.20	7.00	—	23,370	20,900	1.60	7.04	16.10	0.00	0.00	
14	34,270	2.29	7.02	—	23,760	19,660	1.60	7.05	15.90	0.00	0.00	
15	34,200	2.34	6.99	—	23,860	19,120	1.64	7.04	15.90	0.00	0.00	
16	34,190	2.38	6.98	—	23,340	20,350	1.57	7.03	15.90	0.00	0.00	
17	34,200	2.43	6.97	—	22,680	20,520	1.55	6.99	15.80	0.00	0.00	
18	34,400	2.50	6.96	—	23,500	20,380	1.56	7.02	15.70	0.00	0.00	
19	33,960	1.38	6.98	—	22,180	20,440	1.14	7.01	15.60	0.00	0.00	
20	34,740	1.42	6.95	—	22,990	20,580	1.16	7.01	15.70	0.00	0.00	
21	34,620	1.53	6.98	—	22,920	20,050	1.17	7.02	15.50	0.00	0.00	
22	34,450	1.61	6.97	—	22,850	19,930	1.20	7.04	15.50	0.00	0.00	
23	34,020	1.70	6.94	—	22,600	21,150	1.26	7.01	15.50	0.00	0.00	
24	32,470	1.77	6.96	—	21,300	20,270	1.28	6.99	15.60	0.00	0.00	
25	33,120	1.72	6.96	—	22,120	20,610	1.23	7.00	15.50	0.00	0.00	
26	33,520	1.73	6.98	—	21,640	20,990	1.24	7.05	15.40	0.00	0.00	
27	32,820	1.75	6.96	—	21,570	20,520	1.21	7.00	15.40	0.00	0.00	
28	33,100	1.70	6.96	—	22,610	20,350	1.21	6.99	15.30	0.00	0.00	
29	32,800	1.73	6.96	—	22,250	19,940	1.24	7.01	15.20	0.00	0.00	
30	34,180	1.75	6.98	—	22,390	20,980	1.22	7.04	15.10	0.00	0.00	
31	34,240	1.75	6.95	—	23,070	20,560	1.25	7.02	15.00	0.00	0.00	
合計	1,040,620	—	—	—	697,080	630,000	—	—	—	0.00	0.00	
最大	34,740	2.85	7.04	—	23,860	21,150	1.95	7.08	18.50	0.00	0.00	
最小	30,650	1.38	6.92	—	20,810	18,020	1.14	6.95	15.00	0.00	0.00	
平均	33,568	2.13	6.98	—	22,486	20,323	1.51	7.02	16.34	0.00	0.00	

## 初野浄水場 流量水質報告書

平成30年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	34,530	1.80	6.98	—	23,190	20,650	1.25	7.03	14.80	0.00	0.00	
2	35,030	1.91	7.00	—	23,840	20,840	1.38	7.04	14.70	0.00	0.00	
3	33,740	1.94	7.00	—	22,490	20,100	1.38	7.06	14.60	0.00	0.00	
4	34,370	1.98	7.00	—	23,710	19,630	1.41	7.06	14.50	0.00	0.00	
5	35,250	2.02	6.97	—	24,820	20,530	1.39	7.03	14.50	0.00	0.00	
6	34,950	1.99	6.97	—	24,580	20,490	1.44	7.00	14.50	0.00	0.00	
7	33,800	1.94	6.97	—	22,300	20,600	1.35	7.01	14.50	0.00	0.00	
8	32,990	1.93	6.95	—	21,470	20,490	1.33	7.01	14.40	0.00	0.00	
9	34,020	1.86	6.97	—	22,670	21,060	1.30	7.01	14.50	0.00	0.00	
10	32,810	1.84	6.97	—	22,490	20,140	1.29	7.00	14.50	0.00	0.00	
11	33,610	1.77	7.02	—	23,000	19,980	1.16	7.05	14.40	0.00	0.00	
12	33,520	1.79	7.04	—	22,580	19,880	1.17	7.06	14.30	0.00	0.00	
13	34,130	1.80	6.95	—	22,420	20,390	1.23	7.03	14.20	0.00	0.00	
14	34,630	1.91	6.97	—	22,360	20,370	1.25	7.03	14.00	0.00	0.00	
15	33,930	1.93	7.00	—	22,590	20,470	1.25	7.04	13.90	0.00	0.00	
16	33,570	1.99	7.01	—	21,850	20,210	1.20	7.06	13.70	0.00	0.00	
17	33,870	2.14	7.00	—	22,160	20,490	1.26	7.04	13.70	0.00	0.00	
18	33,940	1.99	6.97	—	23,140	19,730	1.27	7.02	13.50	0.00	0.00	
19	33,540	2.14	7.00	—	23,100	19,300	1.31	7.03	13.40	0.00	0.00	
20	33,100	2.11	6.97	—	22,300	20,140	1.34	7.02	13.20	0.00	0.00	
21	34,400	2.14	7.03	—	23,340	20,900	1.36	7.05	13.20	0.00	0.00	
22	34,570	2.24	7.02	—	23,510	20,810	1.24	7.04	13.10	0.00	0.00	
23	33,290	2.20	7.01	—	22,450	20,550	1.14	7.03	12.90	0.00	0.00	
24	33,220	2.23	7.01	—	22,410	19,790	1.26	7.07	12.70	0.00	0.00	
25	33,460	2.27	7.07	—	22,860	19,990	1.34	7.10	12.60	0.00	0.00	
26	32,710	2.02	7.06	—	22,090	19,520	1.33	7.09	12.60	0.00	0.00	
27	32,910	2.04	7.09	—	21,940	20,570	1.25	7.10	12.50	0.00	0.00	
28	32,410	2.04	7.07	—	21,610	20,480	1.33	7.09	12.40	0.00	0.00	
29	33,380	1.99	7.02	—	21,850	21,020	1.28	7.07	12.30	0.00	0.00	
30	33,820	1.98	7.08	—	23,130	20,640	1.17	7.10	12.20	0.00	0.00	
合計	1,013,500	—	—	—	682,250	609,760	—	—	—	0.00	0.00	
最大	35,250	2.27	7.09	—	24,820	21,060	1.44	7.10	14.80	0.00	0.00	
最小	32,410	1.77	6.95	—	21,470	19,300	1.14	7.00	12.20	0.00	0.00	
平均	33,783	2.00	7.01	—	22,742	20,325	1.29	7.05	13.68	0.00	0.00	



## 初野浄水場 流量水質報告書

平成30年12月分

項目 日	原 水 関 係				沈澱池 流量 (m <sup>3</sup> /日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m <sup>3</sup> /日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	33,830	1.97	7.10	—	22,990	20,760	1.19	7.13	12.00	0.00	0.00	
2	33,830	2.13	7.09	—	23,040	20,860	1.22	7.12	11.80	0.00	0.00	
3	33,080	2.16	7.06	—	22,320	19,830	1.26	7.11	11.70	0.00	0.00	
4	33,530	2.15	7.09	—	22,850	20,650	1.23	7.10	11.70	0.00	0.00	
5	33,800	2.14	7.09	—	22,570	21,150	1.11	7.11	11.80	0.00	0.00	
6	33,320	2.14	7.07	—	22,190	20,600	1.16	7.12	11.60	0.00	0.00	
7	33,450	2.02	7.09	—	22,770	20,300	1.18	7.10	11.50	0.00	0.00	
8	33,940	1.96	7.09	—	22,980	21,300	1.14	7.13	11.40	0.00	0.00	
9	33,300	2.05	7.09	—	22,390	20,270	1.21	7.14	11.10	0.00	0.00	
10	33,240	1.99	7.08	—	22,740	20,210	1.21	7.11	10.80	0.00	0.00	
11	33,490	2.34	6.70	—	22,090	20,940	1.43	6.78	7.80	0.00	0.00	
12	35,610	1.64	6.67	—	24,070	21,250	1.34	6.75	7.70	0.00	0.00	
13	34,720	1.38	7.06	—	23,040	21,150	1.28	7.06	9.60	0.00	0.00	
14	34,460	1.29	7.13	—	22,570	21,220	1.14	7.16	10.00	0.00	0.00	
15	34,620	1.32	7.11	—	22,290	21,160	1.12	7.16	9.80	0.00	0.00	
16	34,060	1.32	7.15	—	22,730	20,500	1.10	7.17	9.60	0.00	0.00	
17	34,290	1.32	7.16	—	22,630	20,600	1.11	7.16	9.70	0.00	0.00	
18	34,680	1.39	7.09	—	22,900	21,490	1.16	7.14	9.60	0.00	0.00	
19	33,880	1.45	7.12	—	22,040	20,900	1.20	7.15	9.40	0.00	0.00	
20	34,800	1.44	7.17	—	22,790	21,340	1.19	7.18	9.30	0.00	0.00	
21	34,540	1.51	7.17	—	21,860	20,930	1.24	7.17	9.20	0.00	0.00	
22	34,690	1.54	7.19	—	22,820	21,330	1.24	7.17	9.10	0.00	0.00	
23	34,420	1.61	7.16	—	22,580	20,850	1.28	7.15	9.10	0.00	0.00	
24	34,550	1.67	7.13	—	23,170	20,620	1.42	7.13	9.00	0.00	0.00	
25	34,600	1.80	7.15	—	23,000	20,890	1.56	7.17	8.80	0.00	0.00	
26	34,580	2.00	6.95	—	22,670	21,360	1.73	6.96	8.40	0.00	0.00	
27	34,180	2.02	6.93	—	22,180	21,180	1.74	6.97	8.30	0.00	0.00	
28	34,530	1.92	6.99	—	22,290	20,950	1.63	7.00	8.10	0.00	0.00	
29	35,150	1.90	7.14	—	22,980	21,000	1.51	7.15	8.10	0.00	0.00	
30	33,920	1.95	7.16	—	22,400	19,910	1.60	7.16	7.80	0.00	0.00	
31	34,650	2.01	7.17	—	22,330	20,310	1.60	7.16	7.70	0.00	0.00	
合計	1,059,740	—	—	—	702,270	645,810	—	—	—	0.00	0.00	
最大	35,610	2.34	7.19	—	24,070	21,490	1.74	7.18	12.00	0.00	0.00	
最小	33,080	1.29	6.67	—	21,860	19,830	1.10	6.75	7.70	0.00	0.00	
平均	34,185	1.79	7.08	—	22,654	20,833	1.31	7.10	9.73	0.00	0.00	

## 初野浄水場 流量水質報告書

平成31年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	34,570	2.27	7.09	—	22,020	20,530	1.79	7.11	7.60	0.00	0.00	
2	34,900	2.55	7.04	—	23,560	20,710	1.95	7.10	7.50	0.00	0.00	
3	34,180	2.20	7.09	—	22,800	20,100	1.76	7.10	7.30	0.00	0.00	
4	34,300	2.01	7.13	—	23,090	20,260	1.71	7.14	7.20	0.00	0.00	
5	35,070	2.11	7.14	—	23,470	21,190	1.90	7.13	7.20	0.00	0.00	
6	34,320	2.14	7.15	—	23,270	20,700	1.75	7.11	7.00	0.00	0.00	
7	33,960	2.20	7.13	—	23,010	20,030	1.89	7.14	6.90	0.00	0.00	
8	34,970	2.14	7.18	—	23,010	21,340	1.85	7.16	6.80	0.00	0.00	
9	34,730	2.10	7.12	—	21,970	21,250	1.96	7.15	6.70	0.00	0.00	
10	34,740	2.61	7.16	—	22,800	21,410	2.43	7.17	6.60	0.00	0.00	
11	34,310	2.10	7.19	—	22,180	21,230	2.00	7.18	6.60	0.00	0.00	
12	34,790	2.14	7.22	—	22,980	21,200	2.04	7.16	6.40	0.00	0.00	
13	35,790	2.04	7.24	—	23,520	21,310	1.95	7.18	6.40	0.00	0.00	
14	33,500	1.98	7.26	—	22,290	19,790	1.85	7.22	6.20	0.00	0.00	
15	34,800	1.92	7.28	—	21,640	20,380	1.75	7.23	6.10	0.00	0.00	
16	34,530	1.90	7.23	—	22,970	21,150	1.83	7.20	6.10	0.00	0.00	
17	34,450	2.08	7.24	—	22,280	20,880	1.75	7.20	6.00	0.00	0.00	
18	35,280	1.98	7.28	—	23,430	21,500	1.68	7.21	6.00	0.00	0.00	
19	36,430	2.70	7.32	—	24,240	21,900	2.60	7.27	5.90	0.00	0.00	
20	35,180	2.35	7.34	—	23,730	20,860	2.19	7.26	5.80	0.00	0.00	
21	35,380	2.26	7.35	—	24,140	20,760	2.06	7.27	5.70	0.00	0.00	
22	35,100	2.85	7.35	—	23,370	21,510	2.50	7.29	5.60	0.00	0.00	
23	34,810	2.58	7.36	—	22,740	21,480	2.45	7.27	5.50	0.00	0.00	
24	35,200	2.41	7.34	—	23,260	21,450	2.15	7.26	5.50	0.00	0.00	
25	35,170	3.12	7.36	—	23,070	21,250	2.80	7.30	5.40	0.00	0.00	
26	35,010	2.07	7.39	—	23,460	21,100	2.06	7.31	5.30	0.00	0.00	
27	35,090	2.04	7.40	—	23,870	20,860	1.93	7.31	5.20	0.00	0.00	
28	35,040	2.02	7.37	—	23,220	20,660	1.96	7.40	4.60	0.00	0.00	
29	34,600	2.05	7.39	—	23,360	21,350	1.94	7.33	5.10	0.00	0.00	
30	34,310	4.04	7.39	—	21,990	20,860	4.26	7.33	5.00	0.00	0.00	
31	35,960	3.07	7.40	—	23,490	21,970	3.00	7.32	5.10	0.00	0.00	
合計	1,080,470	—	—	—	714,230	650,970	—	—	—	0.00	0.00	
最大	36,430	4.04	7.40	—	24,240	21,970	4.26	7.40	7.60	0.00	0.00	
最小	33,500	1.90	7.04	—	21,640	19,790	1.68	7.10	4.60	0.00	0.00	
平均	34,854	2.32	7.26	—	23,040	20,999	2.12	7.22	6.14	0.00	0.00	

## 初野浄水場 流量水質報告書

平成31年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,110	3.05	7.38	—	23,110	21,630	2.86	7.30	5.10	0.00	0.00	
2	35,110	3.23	7.40	—	23,520	21,270	3.12	7.33	5.00	0.00	0.00	
3	34,600	3.36	7.41	—	23,080	20,650	3.17	7.31	5.00	0.00	0.00	
4	34,920	3.21	7.41	—	23,310	20,770	3.06	7.32	5.20	0.00	0.00	
5	35,000	4.67	7.40	—	23,480	21,560	4.42	7.32	5.00	0.00	0.00	
6	34,980	3.84	7.41	—	22,820	21,490	3.64	7.32	5.00	0.00	0.00	
7	35,170	3.73	7.42	—	23,710	21,620	3.53	7.33	5.00	0.00	0.00	
8	34,910	3.49	7.40	—	22,480	21,470	3.25	7.33	4.90	0.00	0.00	
9	35,250	3.46	7.40	—	23,840	21,170	3.29	7.32	4.90	0.00	0.00	
10	34,840	3.36	7.39	—	23,480	20,500	3.19	7.34	4.80	0.00	0.00	
11	36,010	3.24	7.41	—	24,270	21,010	3.01	7.33	4.80	0.00	0.00	
12	35,590	3.16	7.39	—	23,280	21,060	3.05	7.34	4.80	0.00	0.00	
13	33,750	3.51	7.42	—	21,510	20,160	3.31	7.32	4.70	0.00	0.00	
14	35,640	3.36	7.40	—	22,780	21,500	3.07	7.35	4.60	0.00	0.00	
15	34,800	3.28	7.41	—	23,220	21,350	3.01	7.31	4.50	0.00	0.00	
16	35,650	3.07	7.45	—	22,670	21,570	2.88	7.34	4.50	0.00	0.00	
17	35,170	3.26	7.42	—	23,370	20,970	2.99	7.35	4.50	0.00	0.00	
18	34,650	3.38	7.40	—	22,770	20,380	3.18	7.33	4.50	0.00	0.00	
19	35,410	3.36	7.45	—	23,650	21,480	2.99	7.33	4.60	0.00	0.00	
20	34,630	3.15	7.43	—	21,270	21,030	2.97	7.31	4.70	0.00	0.00	
21	32,030	3.07	7.51	—	20,960	19,260	2.72	7.68	4.70	0.00	0.00	
22	33,780	2.80	7.49	—	22,370	21,170	2.11	7.64	4.70	0.00	0.00	
23	34,050	2.61	7.53	—	22,980	21,480	2.01	7.64	4.80	0.00	0.00	
24	34,570	2.61	7.52	—	22,810	20,440	1.96	7.63	4.80	0.00	0.00	
25	34,610	2.59	7.55	—	22,660	20,400	1.96	7.68	4.90	0.00	0.00	
26	34,800	2.55	7.53	—	23,000	21,600	1.88	7.66	5.00	0.00	0.00	
27	34,710	2.53	7.53	—	22,620	21,160	1.88	7.64	5.10	0.00	0.00	
28	34,880	2.64	7.52	—	22,470	21,170	1.84	7.64	5.20	0.00	0.00	
合計	974,620	—	—	—	641,490	589,320	—	—	—	0.00	0.00	
最大	36,010	4.67	7.55	—	24,270	21,630	4.42	7.68	5.20	0.00	0.00	
最小	32,030	2.53	7.38	—	20,960	19,260	1.84	7.30	4.50	0.00	0.00	
平均	34,808	3.20	7.44	—	22,910	21,047	2.87	7.42	4.83	0.00	0.00	

## 初野浄水場 流量水質報告書

平成31年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,090	2.64	7.50	—	22,890	21,340	1.92	7.64	5.20	0.00	0.00	
2	36,100	2.55	7.51	—	23,510	22,560	1.82	7.62	5.50	0.00	0.00	
3	33,470	2.58	7.52	—	22,020	19,970	1.88	7.65	5.40	0.00	0.00	
4	34,620	2.67	7.50	—	23,270	20,330	1.94	7.63	5.40	0.00	0.00	
5	34,650	2.54	7.50	—	22,860	21,030	1.86	7.63	5.30	0.00	0.00	
6	33,990	2.61	7.49	—	21,750	20,620	1.88	7.59	5.40	0.00	0.00	
7	35,800	2.21	7.51	—	23,450	22,080	1.61	7.61	5.70	0.00	0.00	
8	34,520	2.45	7.44	—	22,700	20,660	1.75	7.58	5.40	0.00	0.00	
9	34,920	2.40	7.51	—	22,790	21,390	1.83	7.60	5.70	0.00	0.00	
10	34,760	2.34	7.50	—	22,710	21,160	1.66	7.70	5.90	0.00	0.00	
11	34,460	2.20	7.47	—	22,600	20,400	1.63	7.67	5.90	0.00	0.00	
12	34,960	4.06	7.46	—	23,450	21,270	3.05	7.62	6.20	0.00	0.00	
13	34,450	2.93	7.48	—	22,240	21,460	2.39	7.56	6.40	0.00	0.00	
14	34,320	3.33	7.46	—	22,270	21,190	2.36	7.59	6.40	0.00	0.00	
15	35,090	4.38	7.47	—	23,190	21,320	3.37	7.67	6.40	0.00	0.00	
16	35,910	4.44	7.44	—	23,750	21,880	3.46	7.64	5.00	0.00	0.00	
17	35,050	4.06	7.45	—	23,420	20,840	3.15	7.62	6.30	0.00	0.00	
18	35,060	4.06	7.43	—	23,620	20,250	2.99	7.56	6.30	0.00	0.00	
19	35,250	3.72	7.45	—	23,290	21,230	2.96	7.63	6.40	0.00	0.00	
20	35,330	2.97	7.48	—	22,830	21,590	2.11	7.63	6.70	0.00	0.00	
21	35,520	3.00	7.44	—	22,860	21,540	2.10	7.61	6.80	0.00	0.00	
22	35,230	2.91	7.46	—	23,420	19,480	2.09	7.55	7.60	0.00	0.00	
23	34,320	3.43	7.42	—	22,030	17,830	2.25	7.60	7.70	0.00	0.00	
24	30,260	3.00	7.41	—	19,120	17,560	2.21	7.56	6.80	0.00	0.00	
25	32,060	3.38	7.42	—	20,430	14,450	2.35	7.55	6.90	0.00	0.00	
26	32,050	2.96	7.45	—	19,720	16,850	1.98	7.57	7.50	0.00	0.00	
27	31,830	2.76	7.48	—	19,470	16,860	1.86	7.60	7.80	0.00	0.00	
28	32,110	2.79	7.48	—	19,840	16,590	1.93	7.60	7.90	0.00	0.00	
29	32,010	2.69	7.42	—	19,830	16,560	1.96	7.55	7.40	0.00	0.00	
30	32,750	2.77	7.44	—	20,750	17,210	1.89	7.53	7.20	0.00	0.00	
31	31,700	2.54	7.37	—	20,450	16,030	1.81	7.50	6.80	0.00	0.00	
合計	1,057,640	—	—	—	686,530	613,530	—	—	—	0.00	0.00	
最大	36,100	4.44	7.52	—	23,750	22,560	3.46	7.70	7.90	0.00	0.00	
最小	30,260	2.20	7.37	—	19,120	14,450	1.61	7.50	5.00	0.00	0.00	
平均	34,117	3.01	7.46	—	22,146	19,791	2.20	7.60	6.36	0.00	0.00	