


A L P S 処理水に係る海水モニタリングの調査結果（トリチウム迅速分析）

（単位：Bq/L）

調査測点	採水日																							
	R5																		R6					
	8/25	8/30	9/3	9/12	9/19	9/26	10/8	10/12	10/20	10/24	11/3	11/9	11/14	11/22	11/28	12/5	12/15	12/20	1/10	1/18	1/31	2/9	2/15	3/15※1
第一（発）南放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
第一（発）北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
第一（発）取水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
第一（発）沖合2km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
夫沢・熊川沖2km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
双葉・前田川沖2km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ALPS処理水放出口 北2km西0.5km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ALPS処理水放出口 北1km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ALPS処理水放出口 南 1 km	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
検出下限値	3.7～ 4.1	3.9～ 4.4	3.8～ 4.4	3.4～ 4.0	5.0～ 6.3	3.7～ 4.0	3.7～ 4.6	3.8～ 4.5	4.1～ 4.6	4.1～ 4.6	4.2～ 4.6	3.6～ 4.0	4.0～ 4.6	3.6～ 3.9	3.9～ 4.3	4.0～ 4.4	4.3～ 5.1	4.2～ 4.9	3.9～ 4.4	4.1～ 4.7	4.1～ 4.7	4.4～ 4.9	3.7～ 3.9	3.3～ 3.9

※ ：ALPS処理水放出期間中の採水

※1：令和5年度4回目の放出については令和 6 年2月28日から開始されたが、令和6年3月15日0時14分頃発生した地震の影響により同日15時49分まで放出を停止していた。