

初野浄水場 流量水質報告書

令和6年7月分

| 項目 日 | 原 水 関 係 | | | | 沈澱池 流量 (m3/日) | 配 水 関 係 | | | | 薬品注入量(1) | | 記事 |
|---------|---------------|-------------|------|-----------|---------------------|---------------|-------------|------|-------------|----------|-----------|----|
| | 原水量 (m3/日) | 濁度 (ppm) | P H | アルカリ 度 | | 配水量 (m3/日) | 濁度 (ppm) | P H | 水温 (° C) | P A C | 苛性 ソーダ | |
| 1 | 35,270 | 1.33 | 7.13 | — | 24,310 | 18,870 | 0.40 | 7.15 | 13.80 | 0.00 | 0.00 | |
| 2 | 35,270 | 2.40 | 7.10 | — | 23,800 | 20,130 | 0.59 | 7.17 | 13.80 | 0.00 | 0.00 | |
| 3 | 35,890 | 0.92 | 7.09 | — | 23,770 | 20,480 | 0.24 | 7.16 | 13.90 | 0.00 | 0.00 | |
| 4 | 35,850 | 0.88 | 7.08 | — | 23,760 | 20,470 | 0.18 | 7.18 | 13.90 | 0.00 | 0.00 | |
| 5 | 34,580 | 0.88 | 7.08 | — | 22,300 | 19,930 | 0.24 | 7.16 | 13.80 | 0.00 | 0.00 | |
| 6 | 36,310 | 0.88 | 7.08 | — | 22,640 | 20,710 | 0.10 | 7.15 | 13.90 | 0.00 | 0.00 | |
| 7 | 35,450 | 0.85 | 7.09 | — | 21,960 | 19,870 | 0.10 | 7.14 | 13.80 | 0.00 | 0.00 | |
| 8 | 35,280 | 0.82 | 7.06 | — | 21,820 | 20,060 | 0.43 | 7.16 | 13.50 | 0.00 | 0.00 | |
| 9 | 37,570 | 0.99 | 7.06 | — | 25,640 | 21,360 | 0.57 | 7.09 | 13.70 | 0.00 | 0.00 | |
| 10 | 36,000 | 1.15 | 7.06 | — | 24,330 | 18,910 | 0.85 | 7.10 | 13.60 | 0.00 | 0.00 | |
| 11 | 36,390 | 0.92 | 7.02 | — | 23,750 | 20,210 | 0.37 | 7.09 | 13.70 | 0.00 | 0.00 | |
| 12 | 37,240 | 0.85 | 7.07 | — | 24,320 | 20,670 | 0.33 | 7.15 | 13.90 | 0.00 | 0.00 | |
| 13 | 33,750 | 0.83 | 7.07 | — | 22,160 | 18,840 | 1.41 | 7.15 | 14.00 | 0.00 | 0.00 | |
| 14 | 36,010 | 0.82 | 7.04 | — | 24,670 | 19,160 | 0.23 | 7.16 | 14.00 | 0.00 | 0.00 | |
| 15 | 35,390 | 0.85 | 7.03 | — | 24,510 | 19,070 | 0.21 | 7.09 | 13.80 | 0.00 | 0.00 | |
| 16 | 35,370 | 0.91 | 7.06 | — | 24,540 | 18,970 | 0.33 | 7.15 | 14.00 | 0.00 | 0.00 | |
| 17 | 36,390 | 0.86 | 7.05 | — | 23,930 | 20,630 | 0.06 | 7.14 | 14.10 | 0.00 | 0.00 | |
| 18 | 34,760 | 0.88 | 7.08 | — | 23,270 | 19,730 | 0.84 | 7.16 | 14.10 | 0.00 | 0.00 | |
| 19 | 36,740 | 0.84 | 7.04 | — | 24,030 | 20,700 | 0.32 | 7.10 | 14.00 | 0.00 | 0.00 | |
| 20 | 34,070 | 0.82 | 7.05 | — | 22,380 | 19,280 | 0.11 | 7.08 | 14.10 | 0.00 | 0.00 | |
| 21 | 35,770 | 0.79 | 6.99 | — | 24,220 | 19,750 | 0.11 | 7.11 | 13.90 | 0.00 | 0.00 | |
| 22 | 35,590 | 0.77 | 7.01 | — | 23,790 | 19,650 | 0.12 | 7.12 | 14.00 | 0.00 | 0.00 | |
| 23 | 35,790 | 0.70 | 6.96 | — | 23,080 | 20,970 | 0.16 | 7.16 | 13.80 | 0.00 | 0.00 | |
| 24 | 35,240 | 0.77 | 6.98 | — | 22,630 | 20,360 | 0.58 | 7.10 | 13.70 | 0.00 | 0.00 | |
| 25 | 36,170 | 0.78 | 6.96 | — | 24,010 | 20,520 | 0.23 | 7.11 | 13.90 | 0.00 | 0.00 | |
| 26 | 35,280 | 0.77 | 6.98 | — | 23,750 | 19,660 | 0.26 | 7.07 | 14.00 | 0.00 | 0.00 | |
| 27 | 35,760 | 0.82 | 6.91 | — | 23,740 | 19,830 | 0.34 | 7.05 | 13.90 | 0.00 | 0.00 | |
| 28 | 36,140 | 0.85 | 6.94 | — | 25,120 | 19,590 | 0.40 | 7.09 | 14.20 | 0.00 | 0.00 | |
| 29 | 35,510 | 0.86 | 6.93 | — | 24,570 | 19,660 | 0.39 | 7.12 | 14.30 | 0.00 | 0.00 | |
| 30 | 35,800 | 0.85 | 6.90 | — | 24,000 | 20,200 | 0.43 | 7.20 | 14.30 | 0.00 | 0.00 | |
| 31 | 35,990 | 0.82 | 6.93 | — | 23,690 | 20,190 | 0.45 | 7.14 | 14.10 | 0.00 | 0.00 | |
| 合計 | 1,106,620 | | | — | 734,490 | 618,430 | | | | 0.00 | 0.00 | |
| 最大 | 37,570 | 2.40 | 7.13 | — | 25,640 | 21,360 | 1.41 | 7.20 | 14.30 | 0.00 | 0.00 | |
| 最小 | 33,750 | 0.70 | 6.90 | — | 21,820 | 18,840 | 0.06 | 7.05 | 13.50 | 0.00 | 0.00 | |
| 平均 | 35,697 | 0.92 | 7.03 | — | 23,693 | 19,949 | 0.37 | 7.13 | 13.92 | 0.00 | 0.00 | |